


- FIGURED DIMENSIONS ONLY TO BE USED
- COORDINATES BASED ON WGS84
- LEVELS BASED ON MSL DATUM
- DISCREPANCIES, ERRORS AND OMISSIONS ARE TO BE REPORTED TO ENGINEER IMMEDIATELY THEY BECOME EVIDENT.
- SHOP DRAWINGS TO BE SUBMITTED FOR APPROVAL PRIOR TO MANUFACTURE OR INSTALLATION.
- COPYRIGHT AND RIGHT OF REPRODUCTION OF THIS DRAWINGS OR ANY PORTION THEREOF IS RESERVED.

	SWITCH GENERAL SYMBOL
	CIRCUIT BREAKER
	ISOLATOR
	FUSE
	FUSE SWITCH
	FUSE DISCONNECTOR
	TIMER
	WITHDRAWABLE CIRCUIT BREAKER
	EARTH LEAKAGE
	EARTH LEAKAGE RELAY WITH OVERLOAD PROTECTION
	OPERATING DEVICE (UPS)
	TIME SWITCH
	AMMETER
	VOLTMETER
	40A 3PHASE ELECTRONIC METER SIMILAR TO ONEISTO
	GENERATOR
	CURRENT TRANSFORMER
	TRANSFORMER
	40A 3P SURGE ARRESTOR
	REMOTE OCCUPANCY SENSOR
	BUS COUPLER
	DAY NIGHT SWITCH

Client: **THE INNOVATIONHUB®**



SPURTING GROWTH AND DEVELOPMENT AGENCY

Project Title:
Innovation Hub Phase IC
Electrical Services



1. Existing main DB to be upgraded to 400A
2. Existing main DB to be rewired by Contractor as per the engineer's instructions to accommodate additional 200A breaker for second floor
3. Existing main UPS DB to be upgraded to accommodate 40A breaker for second floor
4. Supply cable from main kiosk to be upgraded to 120mm²
5. The installation must comply with SANS 10142-1 latest revision
6. The positions of points might be influenced by built in furniture or structure on site. The contractor must inform the Eng. on any changes that might occur during construction phase